



**WEBINAR  
SERIES**

# Demonstration of a Gas Engine Heat Pump (GEHP) with Scalable Solar Thermal Array in Multi-Family Central Water Heating

Webinar  
June 24, 2021

Energx Controls Incorporated

Tim Krause

Occidental Analytical Group

A. Ahmed

## Project Description

This project will demonstrate an integrated and comprehensive solution for water heating in one multi-family apartment building

The solution combines three technologies

- advanced solar thermal water heating utilizing evacuated tube technology (ETC)
- emerging natural Gas Engine Heat Pump (GEHP) for Domestic Hot Water (DHW) in central water heating
- Energx developed central water heating loop controller


This effort will achieve deep natural gas energy savings, with reduced associated greenhouse gas (GHG) and nitrous oxide (NOX) emissions.

## Project Goals and Objectives

- Achieve at least a 75% reduction in natural gas use in DHW heating
- Demonstrate an integrated solution for achieving the target energy savings and investigate how the combination of technologies and measures can be optimized
- Investigate the performance and cost effectiveness of each of subsystems (ETC and GEHP) operating independently as well.
- Document the baseline and project impacted energy use, emissions.
- Estimate the total cost and conduct cost effectiveness analysis for potential viability as future utility energy efficiency measure or California Title-24 standard
- Address and help meet State of California's policy objectives (AB32, AB758, AB802, SB350, CPUC Energy Efficiency Strategic Plan, the California Energy Code)
- Build awareness through outreach efforts among multifamily property owners of the comprehensive solution to help transform or create the market
- Share lessons learned and technology performance information with stakeholders and in outreach activities such as symposiums and publishing in journals



# PROJECT ORGANIZATION



## Customer and Site

### Participating Customer: Equity Residential

Equity Residential is an S&P 500 company focused on acquisition, development and management of high-quality apartment properties. Equity owns or has investments in 302 properties (77,498 apartment units) located in Boston, New York, Washington DC, Seattle, San Francisco and Southern California.

### Equity's goals are to:

- Reduce energy consumption by 15% and reduce water consumption by 10% of 2011 levels by 2021
- Invest in clean and renewable energy generation technologies that reduce emissions, energy and water use
- Appropriately engage their communities to ensure high levels of customer satisfaction
- Maintain high corporate governance standards and attract, cultivate and retain a diverse work force
- Equity has a keen interest in the technologies being tested in this project as they could be applied in several of their properties.

# Project Schedule and Budget

## Schedule

From the date of approval of contracts, the project should last up to 24 months with the following:

- Baseline Analysis – max two months
- Technology Installation – 4-6 months
- Post installation Monitoring, Final Report, Outreach – 12-14 months

## Budget:


- |                        |            |
|------------------------|------------|
| • Total Project Budget | \$ 946,445 |
| • CEC Funding          | \$ 753,605 |
| • Match Funding        | \$ 192,840 |

# Project Site

- **Park West Apartments**
- **Located at 9400 La Tijera Blvd, Los Angeles, Ca**
- **444 Unit L-Shaped apartment complex with interconnected buildings and a common roof**
- **Four story buildings with two levels of parking beneath**
- **Two swimming pools, one heated**
- **Three hot water boiler systems, 148 apartments/system**
- **Each system with two 750,000 btu Raypak boilers with a 275-gallon storage tank**



# Satellite View of Site






# EQUIPMENT SITING

- Existing DHW piping from boilers are routed to mains in the ground level garage then up a chase and distribution lines feed apartments
- This enabled a point of connection for new hot water piping to be in the ground floor garage level
- The new equipment could be located in a large storage space near the entrance to the garage
- Only the solar hot water piping had to be routed up to the roof
- The garage level also contains all services (DHW, DCW, NG, HW Recirc Line) running along concrete ceiling, enabling easy connections and shorter pipe runs

Large Swimming Pool Area/Garage Entrance



# PHOTOS

- Following pages illustrate site conditions through photographs

# Boilers on Roof





## Piping under first floor/below slab on upper garage



## Parking Garage Showing Piping Above and vertical pipe runs up to apartments





## Equipment Room (was storage)



# Pre-Install M&V Instrumentation



## TECHNOLOGIES

Project focus is on demonstration of three (3) energy efficiency technologies

- Gas Engine Heat Pump (GEHP) water heating
- Evacuated tube solar thermal water heating
- Energx Dual Sensor Water Heater Controller

Technologies are synergistic in that they all can work together to reduce water heating energy use


Target sizing of GEHP +Solar Thermal WH to reduce natural gas use by 60%-75% with additional 5%-10% reduction through use of the Energx controller



# Technology

## Gas Engine Heat Pump (GEHP)- Tecogen

- Ilios HEWH-500-AS
- Twice the efficiency of a conventional boiler
- 400,000 to 600,000 BTU/hour of hot water ideal for DHW, swimming pools, space heating and process heat
- Hot water delivery temperature 100°F to 160°F with near zero criteria pollutants
- COP of up to 2.2 utilizing a highly efficient heat pump with reclaimed engine waste heat
- 50% reduction in carbon footprint
- Ultra-low emissions with near-zero criteria pollutants
- Internal 5 kW generator for parasitic load
- Low-pressure, HFC-134a





# Technology

## Evacuated Tube (ETC) Solar Collector- ErgSol

### Why Evacuated Tube Collectors?

- Flat-plate collectors can be prone to condensation buildup resulting in corrosion
- Because the space inside the tube is a vacuum, ETC have much better heat retention than the glazing/air space (R-7) design of flat-plate collectors.
- ETC are capable of producing higher temperatures overall and can produce more heat in cold weather
- ETC perform much better under cloudy and windy conditions
- Modular design of ETC, individual tubes can easily be replaced
- Evacuated tubes are less sensitive to sun angle and orientation
- Individual tubes can be carried to the location and then assembled in place



# Technology

## Evacuated Tube (ETC) Solar Collector-ErgSol

### Low Profile -

sits flat on roofs and facades

### Utilization of Direct and Diffuse Light -

state-of-the-art for non-concentrating, non-tracking solar thermal design

### Small Footprint -



offer significantly higher energy density per square foot of roof area

### Minimal Wind Load –tubes spaced

### Low Maintenance -Applicable in any climate zone

### Leading Performance -SRCC Clear E=4.039 kWh/m<sup>2</sup>/day

Collector comparison at a solar irradiation of 400 W/m<sup>2</sup>







# Technology


## Energx Dual Sensor Central WH Controller

- Dual Sensor Controller stops short cycling of boilers and water heaters
- Uses digital controls and relays to sense the temperature at two separate locations in the water heating storage tank
- Control is in addition to the existing water heater or boiler controls
- When the system temperature is satisfied nothing is operational or on
- When the tank cools down, the bottom sensor of the tank will call for heat but the burner will not fire until the top sensor calls for heat
- With both sensors calling for heat, the control system is energized and the heater or boiler control system will fire
- When the top sensor is satisfied and the bottom sensor is not satisfied, the control system will stop the water heater or boiler from firing and it stay in stand-by mode until both sensors call for heat
- Energy savings of 10%-15% result from system




# BASELINE M&V

# Baseline EM&V Instrumentation




## Baseline Water Heating Energy Use

- Baseline energy use estimated from gas and ambient temperature measurements shown in this plot (R2 not ideal)
- Annual therms used = 10,069 th/yr
- Annual Emissions from water heating = 111,810 lbs/yr of CO2
- Annual DHW gas cost = \$10,069
- EM&V done by NegaWatt Consulting




# SYSTEM DESIGN

# DESIGN – Existing DHW Schematic




**PARK WEST APARTMENTS, LOS ANGELES**  
**EXISTING DOMESTIC HOT WATER SYSTEM SCHEMATIC**

# DESIGN – Proposed DHW Schematic



**PARK WEST APARTMENTS, LOS ANGELES  
DOMESTIC HOT WATER SYSTEM SCHEMATIC**

# DESIGN – GEHP Air Flow Management



GEHP ELEVATION SHOWING  
AIR FLOW MANAGEMENT

SCALE 1/2"=1'-0"



## POST INSTALLATION PHOTOS


- Following pages illustrate equipment installation through photographs












# Post-Installation M&V


# GEHP Heat Input and Output

Hourly GEHP Heat Input and Output



# GEHP Temperatures


Hourly GEHP Supply Temperature, Return Temperature, and Delta T





# GEHP COP

Hourly GEHP COP





## Project M&V Summary of Findings

- The GEHP is successfully providing heat as shown by the steady delta T of about 10 F.
- The COP is lower than expected but it is trending higher. This may be due to minor differences in the DHW load.
- We expect that adding booster fans will improve the COP
- Solar and Energx controller performance has not been properly mapped – activities has been focused on troubleshooting GEHP performance
- Detailed M&V report on GEHP, Solar Thermal and Energx Controller performance will be available once project study is completed

# Project Experience

## Project Experience – GEHP Performance

- GEHP performance has been a challenge since the installation experienced reduced air flow through the evaporator coils
- Air flow measurements with Tecogen present showed that the fans were delivering half of the 22,000 cfm as required by Tecogen
- When the ducts were removed, the air flow improved to about 14,000 cfm still not enough and measured COP was around 1.0
- With just 34 inches between top of unit and garage ceiling, the exhaust fans are not capable of delivering the required cfm
- A solution is to re-install the ducts with in-line booster fans to get the required air flow across the coils
- As project funds were depleted, Energx requested SoCalGas ETP funding to get the project over this final hurdle
- SoCalGas agreed to fund this second phase of the project

# Project Experience – GEHP Performance



## Project Experience

- It is a complex project that requires a lot of coordination
- Several delays occurred - site change by Equity, approvals by CEC
- Site equipment location was a challenge and because of GEHP noise and emissions consideration. Took several site visits
- Equipment with GEHP, storage tank, heat exchangers and pumps require adequate space and space is a premium in existing high-end apartment complex
- Unusually long design phase-required Los Angeles Department of Building Services (LADOBS) review and approval of plans
- Months of delay due to COVID inactivity

## NEXT STEPS – Phase II

- Project received additional funding from SoCalGas ETP
- Energx/Mission Aire to begin installing booster fans in ducts to increase air flow through evaporator coils
- Continue post-install M&V
- Complete project M&V and submit final report by March, 2022



## Technology Transfer Activities

After completion of project study, the following activities are planned:

- Develop Presentation Materials on the project for Energy Commission- sponsored conference/workshop(s)
- Take High Quality Digital Photographs of the project for publishing
- Develop a technology transfer plan for the CEC with Fact Sheet
- Participate in technology transfer activities such as presentations in energy symposiums and forums (ESC, ESource, ACEEE, CEE)
- Publish articles in scientific journals

This project is funded by the California Energy Commission's Public Interest Energy Research (PIER) program.

For more information, contact Mr. Amir Ehyai at [Amir.Ehyai@energy.ca.gov](mailto:Amir.Ehyai@energy.ca.gov)  
The project final report will be uploaded to CEC Website and the ETCC website



Thank You

Q & A